



NUMBERED NOTES:

- ① CONNECT NEW 1" C.W. TO EXISTING 1" C.W. W/ SHUT-OFF VALVE.
- ② REINSULATE ALL EXISTING H. & C.W. PIPING WITHIN EXISTING REPAIR GARAGE. VERIFY EXACT QUANTITY AND SIZE.

GENERAL NOTES:

- 1 - GAS VENT FROM UNIT HEATERS TO BE STAINLESS STEEL PRESSURE PIPE.
- 2 - VENT ALL GAS PRESSURE REGULATORS TO THE BUILDING EXTERIOR.
- 3 - GAS VENT FROM UNIT HEATERS UH-4 THRU UH-7 TO BE 4"Ø TO COMBINED 8"Ø UP THRU ROOF.

This drawing was prepared by:
Wentz Associates, Inc.
 7300 France Avenue South
 Suite 330
 Minneapolis, MN 55435
 Telephone: (612) 831-1180
 Fax: (612) 831-2179

I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATION, OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.
Thomas A. Watz
 DATE 09 OCT 95 REG. NO. 18808



1326 ENERGY PARK DRIVE
 ST. PAUL, MINNESOTA 55108
 (612) 644-4389
 9800 SHELARD PARKWAY
 MINNEAPOLIS, MINNESOTA 55441
 (612) 546-0432

DATE	DESCRIPTION	DESIGNED	TAW
		CHECKED	TAW
		DRAWN	SRS
		GRAPHIC SCALE	
		0	HORIZ. 8
		0	VERT. 1

CITY OF ELK RIVER
 WASTEWATER TREATMENT FACILITIES
 MAIN BUILDING MECHANICAL PLAN

DATE OCT 1995 SHEET M7 OF M11 SHEETS PROJECT NO. 230-151