



- NOTES**
1. THE CONTRACTOR SHALL SUBMIT THE CONCRETE POURING SEQUENCE TO THE ENGINEER PRIOR TO THE FIRST CONCRETE POUR. SUCH REVIEW SHALL NOT RELIEVE THE CONTRACTOR OF ANY RESPONSIBILITY FOR THE POURING SEQUENCE OR METHODS OF PLACEMENT.
 2. SLAB & WALL PANELS SHALL BE ALLOWED TO CURE 14 DAYS BEFORE ADJACENT PANELS ARE POURED.
 3. BACKFILLING OPERATIONS FOR ALL EXTERIOR WALLS SHALL BE CARRIED ON SIMULTANEOUSLY IN EQUAL LIFTS AND ONLY AFTER THE BASE SLAB IS IN PLACE AND CURED, AND AFTER ERECTION OF ALL DT ROOF PANELS.

DIGESTED SLUDGE STORAGE TANK PLAN @ ELEV. 900'-0"
 Scale: 1/4" = 1'-0"

I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATION, OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.
David L. Cahill
 DATE 11/18/95 REG. NO. 22222



1326 ENERGY PARK DRIVE
 ST. PAUL, MINNESOTA 55108
 (612) 644-4389
 9800 SHELARD PARKWAY
 MINNEAPOLIS, MINNESOTA 55441
 (612) 546-0432

REVISIONS	DATE	DESCRIPTION

DESIGNED	DLC	GG
CHECKED	LJL	GG
DRAWN	GG	GG
GRAPHIC SCALE		
0	HORIZ.	4
0	VERT.	4

CITY OF ELK RIVER
 WASTEWATER TREATMENT FACILITY UPGRADE
 DIGESTED SLUDGE STORAGE TANK
 PLAN @ ELEV. 900'-0"

S21

Wed Nov 8 10:13:39 1995

ER151-32