



**NOTE**  
THE SECONDARY DIGESTER SHALL BE CLEANED WITH HIGH PRESSURE WATER BLASTING TO EXPOSE THE ORIGINAL STRUCTURE AND METAL SURFACE OF DOME. ADEQUATE VENTILATION SHALL BE PROVIDED FOR INSPECTION OF THE DIGESTER INTERIOR. THE CONTRACTOR SHALL RECEIVE APPROVAL BY THE ENGINEER PRIOR TO BEGINNING PIPING WORK ON DIGESTER.

INSTALL A DUAL FUEL BOILER AND RECONNECT ALL PIPING, ELEC. SERVICE, FUEL LINES AND AIR VENT NECESSARY FOR A COMPLETE INSTALLATION.

REMOVE EXIST. FUEL OIL BOILER AND SEWAGE GAS BOILER. PROVIDE BLIND FLANGES OR CAPS TO THE DISCONNECTED PIPING.

I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATION, OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.  
DATE 11/18/95 REG. NO. 22610



1326 ENERGY PARK DRIVE  
ST. PAUL, MINNESOTA 55108  
(612) 644-4389  
9800 SHELARD PARKWAY  
MINNEAPOLIS, MINNESOTA 55441  
(612) 546-0432

DATE	DESCRIPTION	DESIGNED BC
		CHECKED TAR
		DRAWN TB GG
		GRAPHIC SCALE
		0 HORIZ. 2.67
		0 VERT. 2.67

CITY OF ELK RIVER  
WASTEWATER TREATMENT FACILITY UPGRADE  
DIGESTER BUILDING  
PROCESS PIPING MODIFICATIONS

P17